

### Legal Notice

Sealed bids will be received at the Office of the Mayor, Medina City Municipal Building, located at 132 North Elmwood Ave., Medina, Ohio until 10:00 a.m. (Ohio time) on March 10, 2015 for the purchase of Service Department materials for the City of Medina located at 132 North Elmwood Ave., in the City of Medina, Ohio according to the specifications on file in the Office of the Mayor and available to all prospective bidders.

All bids must be accompanied by a Bid Bond or Certified Check payable to the order of the City of Medina, Ohio, in the sum of ten percent (10%) of the bid amount as a guarantee that if such bid is accepted, the bidder will deliver the materials according to the given specifications or in default thereof, said check will be forfeited to the City of Medina as liquid damages.

The City of Medina reserves the right to reject any and all bids and to waive any informality in the bidding process.

Signed: Nino Piccoli, Service Director

Gazette:

February 24, 2015

March 3, 2015

**SPECIFICATION FOR CHEMICALS TO BE PURCHASED  
FOR USE BY THE CITY OF MEDINA WATER DEPARTMENT  
DURING 2015**

Date: \_\_\_\_\_

**(1) LIQUID CHLORINE:**

Approximately 3000 lbs. in 150 lb. cylinders      Bid Price \_\_\_\_\_ per pound.

Liquid chlorine is to be delivered to the Spieth Road Pump Station as needed during the year. The Liquid chlorine shall be such as is commercially available in the form of liquified elemental chlorine gas. In liquid state, the chlorine shall be amber colored and about 1.5 times as heavy as water. Liquid chlorine shipping containers shall conform to applicable regulations of the Interstate Commerce Commission.

The containers shall be reconditioned, maintained and loaded in strict accordance with the latest edition of "Container Procedure at Chlorine Packaging Plants" issued by the Chlorine Institute, Inc. The chlorine shall be ninety-nine and five-tenths percent (99.5%) pure by volume as obtained from vaporized liquid chlorine, and shall be suitable for the treatment of water. The chlorine shall be free of excessive concentration of impurities such as bromine, nitrogen tetroxide, silicon, tetrachloride and sulfuric acid. The chlorine shall conform in all respect to A.W.W.A. Standard No. 8301-59 for Liquid Chlorine as issued by the American Water Works Association.

All chemicals supplied shall conform with the "American National Standards Institute/National Sanitation Foundation" (ANSI/NSF) standard 60 or 61. Any organization certified by the "American National Standards Institute" may certify in writing that a product conforms with these standards.

Bids will be received for chlorine delivered in 150-lb containers.

The price bid shall be based on the delivery of six (6) 150-lb cylinders delivered F.O.B. City of Medina, Spieth Road Pump Station, 8141 Spieth Road, Litchfield, Ohio, between the hours of 7:00 a.m. and 3:00 p.m., Monday through Friday. All shipments must be received within 3 days of the specified delivery date.

**SPECIFICATION FOR CHEMICALS TO BE PURCHASED  
FOR USE BY THE CITY OF MEDINA WATER DEPARTMENT  
DURING 2015**

THE CITY OF MEDINA RESERVES THE RIGHT TO REJECT ANY AND ALL BIDS.

Signed \_\_\_\_\_

By \_\_\_\_\_

Address \_\_\_\_\_

\_\_\_\_\_

Phone \_\_\_\_\_

Fax \_\_\_\_\_